PART 1 GENERAL

1.1 RELATED SECTIONS

- .1 Section 01 33 00 Submittal Procedures.
- .2 Section 06 10 00 Rough Carpentry.
- .3 Section 07 31 13 Asphalt Shingles
- .4 Section 07 62 00 Sheet Metal Flashing and Trim.
- .5 Section 07 92 00 Joint Sealants.

1.2 REFERENCES

- .1 The Aluminum Association Inc. (AA)
 - .1 Aluminum Sheet Metal Work in Building Construction.
 - .2 AA DAF45, Designation System for Aluminum Finishes.
- .2 American Society for Testing and Materials (ASTM International)
 - .1 ASTM A653/A653M, Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process.
 - .2 ASTM A792/A792M, Standard Specification for Steel Sheet, 55% Aluminum-Zinc Alloy-Coated by the Hot-Dip Process.
 - .3 ASTM D523, Standard Test Method for Specular Gloss.
 - .4 ASTM D822, Standard Practice for Filtered Open-Flame Carbon-Arc Exposures of Paint and Related Coatings.
- .3 Canadian General Standards Board (CGBS)
 - .1 CAN/CGSB-37.5, Cutback Asphalt Plastic Cement.
- .4 Canadian Standards Association (CSA International)
 - .1 CSA B111, Wire Nails, Spikes and Staples.

1.3 SUBMITTALS

- .1 Submit duplicate 50 x 50 mm samples of each type of sheet metal material, colour and finish.
- .2 Clearly indicate bending, folding, jointing, fastening installation details.

1.4 DELIVERY AND STORAGE

.1 Store products off ground and under cover in a dry, well ventilated enclosure.

- .2 Stack pre-formed material in manner to prevent twisting, bending and rubbing.
- .3 Provide protection for galvanized and pre-coated surfaces.
- .4 Prevent contact of dissimilar metals during storage. Protect from acids, flux, and other corrosive materials and elements.

PART 2 PRODUCTS

2.1 MATERIALS

- .1 Sheet aluminum 0.64 mm thick. Color as selected by Owner's Representative.
- .2 Trough size: 125 mm wide.
- .3 Trough Supports: continuous aluminum with a perforated aluminum cover that covers the complete trough to prevent debris from getting stuck in the trough and downpipe.
- .4 Downpipes: 0.64 mm thick aluminum.
- .5 Downpipe straps: 0.72 mm thick aluminum.
- .6 Sealant: As per Section 07 92 00 Joint Sealants.
- .7 Elbows and tees: aluminum same as trough.

2.2 FABRICATION

- .1 Fabricate sheet aluminum work in accordance with Aluminum Association Aluminum Sheet Metal Work in Building Construction.
- .2 Fabricate eavestrough in continuous length up to a maximum length of 12 metres.
- .3 Form eavestrough to an Ogee profile, 125 mm wide and a 305 mm girth.

PART 3 EXECUTION

3.1 INSTALLATION

- .1 Install trough supports/debris catchers to provide a continuous slope to drain all water from the trough.
- .2 Cut opening in the trough to receive the downpipes.

- .3 Install the trough and snap in to the supports (no exposed screws or nails permitted). Install elbows and tees as required. Provide for expansion joints to prevent warping where required.
- .4 Install aluminum downpipes to a distance of 1.5 metres from the grade. Install aluminum straps 1200 mm o.c designed to match the pipe profile and fasten to building with aluminum or stainless steel screws.
- .5 Install sewer type downpiping from the aluminum downpiping to a point 300 mm above the grade. Install aluminum straps designed to suit the pipe profile and fasten to the wall with aluminum or stainless steel screws.
- .6 Install sealant as required to ensure all joints are watertight.
- .7 When work is completed, provide a water test to ensure there are no leaks and that all the water runs from the trough.

3.2 CLEANING

- On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Leave works areas clean, free from grease, finger marks and stains.

END OF SECTION