

Electrical - Addendum No. 1

Date: June 22nd, 2017

Page: 1 of 1

Project: Kevlar Commercial Plaza (3000 Wellington Road, Kemptville)

This Addendum forms part of the contract documents and is to be read, interpreted and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof.

Clarification:

- 1.1 Please refer to the Revised Hydro One design for the above mentioned project, the following change has been made by Hydro one.
(The Zone Planner has determined that Hydro will require two, 3ph transformers to feed the site in its entirety. Therefore, I have removed the 2nd, future vault requirement on the design and updated the Detail.)

End of Addendum.