

# Addendum No. 2

Date: March 26, 2018

Total # of Pages: 1

**Project: New Automotive Dealership**  
**5835 Hazeldean Road, Stittsville**

This Addendum forms part of the contract documents and is to be read, interpreted and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof.

## General

2.1 **The tender closing date has been changed to Wednesday, March 28, 2018 @ 3:00pm!!!**

## Architectural

2.2 Drawing A101 has now been re-issued. (Dated March 26, 2018)

2.3 The fire rated assembly separating the General Office from Service has been relocated to accommodate the large aluminum window overlooking the showroom (located along gridline 2).

2.4 Door GO5 is to have a 90 minute fire rating with a small 6" x 16" GWG lite. Delete sidelight from this door frame.

2.5 The fire shutter has been deleted from above Door G05 (a fire shutter is still required above aluminum window in General Office overlooking service bays)

## Electrical

2.6 Electrical drawing E-1 has been re-issued by M&E Engineering, dated March 26 / 18. Changes include the relocation of the incoming Hydro / Bell / Cable services and revisions to the electrical distribution diagram.

**End of Addendum.**