



M&E ENGINEERING

Division of 1436868 Ontario Ltd.

generalmail@meengineering.ca
205 Kincardine Drive
Kanata, Ontario, K2V1C5

Mechanical & electrical professional engineers
Tel: (613) 836-3420
Fax: (613) 836-5957

Addendum No. ME-1

Date: March 23, 2018
Project: Automotive Dealership
Project location: 5835 Haazeldean Rd., Ottawa, Ontario

Electrical:

1. On drawing E-1, light pole shall be steel c/w pre-hole for security camera installation; height to be coordinated with the security contractor.
2. Pole mounted receptacles are not required.
3. CO/NO2 system installation and test and report are part of the electrical scope of work.
4. Light fixture in universal washroom, shop washroom and secured storage shall be type 'A' c/w drywall kit.
5. Delete light fixture under stairs.

HVAC:

1. Provide power exhaust option on the roof top unit.